

**Commonwealth of Kentucky  
Natural Resources and Environmental Protection Cabinet  
Department for Environmental Protection  
Division for Air Quality  
803 Schenkel Lane  
Frankfort, Kentucky 40601  
(502) 573-3382**

**AIR QUALITY PERMIT**

**Permittee Name:** HARTCO Hardwood Flooring, L. P.  
**Mailing Address:** 5031 Industry Road, Somerset, KY 42501

**Source Name:** Same  
**Mailing Address:** Same

**Source Location:** Same

**Permit Type:** Federally-Enforceable  
**Review Type:** Title V

**Permit Number:** V-99-041  
**Log Number:** F927  
**Application  
Complete Date:** January 21, 1999

**KYEIS ID #:** 105-3460-0074  
**AFS Plant ID #:** 21-199-00074  
**SIC Code:** 2426

**Region:** South Central  
**County:** Pulaski

**Issuance Date:** February 2, 2000  
**Expiration Date:** February 2, 2005

## TABLE OF CONTENTS

<u>SECTION</u>		<u>DATE OF ISSUANCE</u>	<u>PAGE</u>
SECTION A	PERMIT AUTHORIZATION	February 2, 2000	1
SECTION B	EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS	February 2, 2000	2
SECTION C	INSIGNIFICANT ACTIVITIES	February 2, 2000	6
SECTION D	SOURCE EMISSION LIMITATIONS AND TESTING REQUIREMENTS	February 2, 2000	7
SECTION E	SOURCE CONTROL EQUIPMENT OPERATING REQUIREMENTS	February 2, 2000	8
SECTION F	MONITORING, RECORD KEEPING, AND REPORTING REQUIREMENTS	February 2, 2000	9
SECTION G	GENERAL CONDITIONS	February 2, 2000	12
SECTION H	ALTERNATE OPERATING SCENARIOS	February 2, 2000	17
SECTION I	COMPLIANCE SCHEDULE	February 2, 2000	18

## **SECTION A - PERMIT AUTHORIZATION**

Pursuant to a duly submitted application which was determined to be complete on January 21, 1999, the Kentucky Division for Air Quality hereby authorizes the operation of the equipment described herein in accordance with the terms and conditions of this permit. This permit has been issued under the provisions of Kentucky Revised Statutes Chapter 224 and regulations promulgated pursuant thereto.

The permittee shall not construct, reconstruct, or modify any affected facilities without first having submitted a complete application and receiving a permit for the planned activity from the permitting authority, except as provided in this permit or in the Regulation 401 KAR 50:035, Permits.

Issuance of this permit does not relieve the permittee from the responsibility of obtaining any other permits, licenses, or approvals required by this Cabinet or any other federal, state, or local agency.

## **SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS**

### **01, 02 (01, 02)      Wood-fired indirect heat exchangers with natural gas secondary fuel**

**Description:** Two Hurst Boilers, Model M-2275-150-DF, with multiclone dust collectors for particulate control, also by Hurst, with guaranteed emission of 0.2 lbs. pm/mmBTU or less.  
Heat input capacity: 16.74 mmBTU/hr each  
Installed: April 1990

**APPLICABLE REGULATIONS:** 401 KAR 59:015, New indirect heat exchangers, applies to affected facilities constructed on or after April 9, 1972 with a capacity of 250 mmBTU/hr heat input or less with respect to particulate emissions and sulfur dioxide emissions.

1. **Operating Limitations:** Equipment and controls shall be operated in such manner as to assure compliance with the emission limitations in Section B2 below.
2. **Emission Limitations:**
  - a) Particulate emissions shall not exceed 0.42 lbs/mmBTU actual heat input. (Section 4)
  - b) Emissions shall not exceed 20% opacity. (Section 4)
  - c) SO<sub>2</sub> emissions shall not exceed 2.93 lbs/mmBTU actual heat input while burning wood.  
SO<sub>2</sub> emissions shall not exceed 1.83 lbs/mmBTU actual heat input while burning natural gas. (Section 5)

#### **Compliance Demonstration Method:**

For Wood Burning:    VOC (lbs) = 0.22 X tons of wood burned  
                              NO<sub>x</sub> (lbs) = 1.5 X tons of wood burned  
                              CO (lbs) = 7.0 X tons of wood burned  
                              SO<sub>2</sub> (lbs) = 0.075 X tons of wood burned  
                              PM<sub>10</sub> (lbs) = 1.76 X tons of wood burned

For Natural Gas:      VOC (lbs) = 2.8 X million cubic feet burned  
                              NO<sub>x</sub> (lbs) = 140 X million cubic feet burned  
                              CO (lbs) = 35 X million cubic feet burned  
                              SO<sub>2</sub> (lbs) = 0.6 X million cubic feet burned  
                              PM<sub>10</sub> (lbs) = 2.74 X million cubic feet burned

**SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS (CONTINUED)**

3.     **Testing Requirements:** See Section D
4.     **Specific Monitoring Requirements:** See Section F
5.     **Specific Recordkeeping Requirements:** The permittee shall keep monthly records of tons of wood burned, and millions of cubic feet of natural gas burned.
6.     **Specific Reporting Requirements:** Refer to Section F
7.     **Specific Control Equipment Operating Conditions:** Refer to Section E.
8.     **Alternate Operating Scenarios:** None

## **SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS (CONTINUED)**

**04 (04, 05, 06, 07)**

Finish lines A & B for wood flooring

**Description:** Finish lines A & B which are identical, consist of stain, sealer and topcoat applied by rollers, with an associated drying oven after each applicator.

### **APPLICABLE REGULATIONS: None**

1. **Operating Limitations:** Equipment shall be operated in such manner as to assure compliance with the emission limitations in Section D.
2. **Emission Limitations:** See Section D
3. **Testing Requirements:** See Section D
4. **Specific Monitoring Requirements:** See Section F
5. **Specific Recordkeeping Requirements:**
  1. The permittee shall keep monthly records of gallons of stains, sealers, topcoats, and thinners applied.
  2. Records shall show density and weight percentage of VOC and HAP for each material applied as well as a rolling 12 month total of tons of VOC's and HAPS emitted.
  3. Tons of HAP emissions shall be recorded by individual HAP and summarized monthly as well as totaled per rolling 12 month period.
  4. All purchase orders and invoices for materials containing VOCs and HAPs shall be made available for inspection upon request by any duly authorized representative of the Division for Air Quality.
  5. All records shall be retained for a period of five years.
6. **Specific Reporting Requirements:** See Section F.
7. **Specific Control Equipment Operating Conditions:** See Section E.
8. **Alternate Operating Scenarios:** None

**SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS (CONTINUED)**

**08 (08, 09)**                      Panel pressing and veneer splicing using adhesive

**Description:** Veneer sheets are glued edge to edge in a single ply, then glued to a two-ply base and pressed.

**APPLICABLE REGULATIONS: None**

1.     **Operating Limitations:** Equipment shall be operated in such manner as to assure compliance with the emission limitations in Section D.
2.     **Emission Limitations:** See Section D
3.     **Testing Requirements:** See Section D
4.     **Specific Monitoring Requirements:** See Section F
5.     **Specific Recordkeeping Requirements:**
  1. The permittee shall keep monthly records of gallons of glue applied.
  2. Records shall show weight percentage of VOC and HAP for glue applied as well as a rolling 12 month total of tons of VOC's and HAPS emitted.
  3. Tons of HAP emissions shall be recorded by individual HAP and summarized monthly as well as totaled per rolling 12 month period.
  4. All purchase orders and invoices for glue containing VOCs and HAPs shall be made available for inspection upon request by any duly authorized representative of the Division for Air Quality.
  5. All records shall be retained for a period of five years.
6.     **Specific Reporting Requirements:** See Section F.
7.     **Specific Control Equipment Operating Conditions:** N.A.
8.     **Alternate Operating Scenarios:** None

**SECTION C - INSIGNIFICANT ACTIVITIES**

The following listed activities have been determined to be insignificant activities for this source pursuant to Regulation 401 KAR 50:035, Section 5(4). While these activities are designated as insignificant the permittee must comply with the applicable regulation and some minimal level of periodic monitoring may be necessary.

<u>Description</u>	<u>Generally Applicable Regulation</u>
1. EP 03- Woodworking Operations	401 KAR 59:010 (See Section E for conditions)
2. Veneer Dryer - 11mmBTU/hr	None
3. Evaporator for Washwater	None



## **SECTION D - SOURCE EMISSION LIMITATIONS AND TESTING REQUIREMENTS**

1. Sourcewide emissions of Volatile Organic Compounds (VOC's) shall not exceed 230 tons per rolling 12 month total.
2. VOC emissions, as measured by methods referenced in 401 KAR 50:015, Section 1, shall not exceed the respective limitations specified herein.
3. Compliance with annual emissions and processing limitations imposed pursuant to 401 KAR 50:035, Section 7(1)(a), and contained in this permit, shall be based on emissions and processing rates for any twelve (12) consecutive months.
4. The permittee shall submit a **semi-annual** report to the division's London Field Office which shows the total amount of each HAP and/or VOC containing material used at the source. The report shall contain emission rates for these materials and a monthly summary of air pollutants emitted from these materials, as well as a rolling 12 month total for each pollutant. Sample calculations shall be included.  
The report shall be submitted no later than thirty days after the six month anniversary of permit issuance, and each six months thereafter. The report may also coincide with reporting required in **Section F.5**, and the annual compliance certification required in **Section F.7**.

This semi-annual report shall be signed by a responsible official certifying the truth and accuracy of the information stated therein.

## **SECTION E - SOURCE CONTROL EQUIPMENT REQUIREMENTS**

1. Pursuant to 401 KAR 50:055, Section 2(5), at all times, including periods of startup, shutdown and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the division which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.
  2. For point 03, the wood working operation, which consists of :
    - a) Associated with baghouse #1: Hasko end matcher, Strip rip/trim saw, Strip finish sander, Strip-finish line, denib and scrubbers
    - b) Associated with baghouse #2: Strip top/bottom dimension sander, strip dimension top sander, strip #1 side matcher
    - c) Associated with baghouse #3: Strip #2 side matcher, Plank- rip/trim saw, Plank- top/bottom dimension sander
    - d) Associated with baghouse #4: Plank- side/end matcher, Strip- end matcher, Plank- finish line, denib and scuffers
    - e) Associated with baghouse #5: Veneer mill- Scrap hog, V-mill- dimension sander, V-mill- top sander, V-mill- straight line saw/jointer
1. Pressure drop at the baghouses shall be read once per operating day.
  2. A log of pressure drop readings which denotes the date, time, and identity of the inspecting personnel shall be kept. Any repairs performed or problems noted shall also be recorded.
  3. Baghouses shall be maintained and operated in accordance with manufacturer's specifications and recommendations

## **SECTION F - MONITORING, RECORD KEEPING, AND REPORTING REQUIREMENTS**

1. When continuing compliance is demonstrated by periodic testing or instrumental monitoring, the permittee shall compile records of required monitoring information that include:
  - a. Date, place as defined in this permit, and time of sampling or measurements.
  - b. Analyses performance dates;
  - c. Company or entity that performed analyses;
  - d. Analytical techniques or methods used;
  - e. Analyses results; and
  - f. Operating conditions during time of sampling or measurement;
2. Records of all required monitoring data and support information, including calibrations, maintenance records, and original strip chart recordings, and copies of all reports required by the Division for Air Quality, shall be retained by the permittee for a period of five years and shall be made available for inspection upon request by any duly authorized representative of the Division for Air Quality. [401 KAR 50:035, Permits, Section 7(1)(d)2 and 401 KAR 50:035, Permits, Section 7(2)(c)]
3. In accordance with the requirements of Regulation 401 KAR 50:035, Permits, Section 7(2)(c) the permittee shall allow the Cabinet or authorized representatives to perform the following:
  - a. Enter upon the premises where a source is located or emissions-related activity is conducted, or where records are kept;
  - b. Have access to and copy, at reasonable times, any records required by the permit:
    - i. During normal office hours, and
    - ii. During periods of emergency when prompt access to records is essential to proper assessment by the Cabinet;
  - c. Inspect, at reasonable times, any facilities, equipment (including monitoring and pollution control equipment), practices, or operations required by the permit. Reasonable times shall include, but are not limited to the following:
    - i. During all hours of operation at the source,
    - ii. For all sources operated intermittently, during all hours of operation at the source and the hours between 8:00 a.m. and 4:30 p.m., Monday through Friday, excluding holidays, and
    - iii. During an emergency; and
  - d. Sample or monitor, at reasonable times, substances or parameters to assure compliance with the permit or any applicable requirements. Reasonable times shall include, but are not limited to the following:
    - i. During all hours of operation at the source,
    - ii. For all sources operated intermittently, during all hours of operation at the source and the hours between 8:00 a.m. and 4:30 p.m., Monday through Friday, excluding holidays, and
    - iii. During an emergency.
4. No person shall obstruct, hamper, or interfere with any Cabinet employee or authorized representative while in the process of carrying out official duties. Refusal of entry or access may constitute grounds for permit revocation and assessment of civil penalties.

**SECTION F - MONITORING, RECORD KEEPING, AND REPORTING REQUIREMENTS (CONTINUED)**

5. Reports of any monitoring required by this permit shall be reported to the division's London Regional Office no later than the six-month anniversary date of this permit and every six months thereafter during the life of this permit, unless otherwise stated in this permit. The permittee may shift to semi-annual reporting on a calendar year basis upon approval of the regional office. If calendar year reporting is approved, the semi-annual reports are due January 30th and July 30th of each year. All reports shall be certified by a responsible official pursuant to Section 6(1) of Regulation 401 KAR 50:035, Permits. All deviations from permit requirements shall be clearly identified in the reports.
6.
  - a. In accordance with the provisions of Regulation 401 KAR 50:055, Section 1 the owner or operator shall notify the Division for Air Quality's London Regional Office concerning startups, shutdowns, or malfunctions as follows:
    1. When emissions during any planned shutdowns and ensuing startups will exceed the standards notification shall be made no later than three (3) days before the planned shutdown, or immediately following the decision to shut down, if the shutdown is due to events which could not have been foreseen three (3) days before the shutdown.
    2. When emissions due to malfunctions, unplanned shutdowns and ensuing startups are or may be in excess of the standards notification shall be made as promptly as possible by telephone (or other electronic media) and shall cause written notice upon request.
  - b. In accordance with the provisions of Regulation 401 KAR 50:035, Section 7(1)(e)2, the owner or operator shall report emission related exceedances from permit requirements including those attributed to upset conditions (other than emission exceedances covered by general condition 6 a. above) to the Division for Air Quality's London Regional Office within 30 days. Other deviations from permit requirements shall be included in the semiannual report required by general condition F.5.
7. Pursuant to Regulation 401 KAR 50:035, Permits, Section 7(2)(b), the permittee shall certify compliance with the terms and conditions contained in this permit, annually on the permit issuance anniversary date or by January 30th of each year if calendar year reporting is approved by the regional office, by completing and returning a Compliance Certification Form (DEP 7007CC) (or an approved alternative) to the Division for Air Quality's London Regional Office and the U.S. EPA in accordance with the following requirements:
  - a. Identification of each term or condition of the permit that is the basis of the certification;
  - b. The compliance status regarding each term or condition of the permit;
  - c. Whether compliance was continuous or intermittent; and
  - d. The method used for determining the compliance status for the source, currently and over the reporting period, pursuant to 401 KAR 50:035, Section 7(1)(c),(d), and (e).

## **SECTION F - MONITORING, RECORD KEEPING, AND REPORTING REQUIREMENTS (CONTINUED)**

- e. The certification shall be postmarked by the thirtieth (30) day following the applicable permit issuance anniversary date, or by January 30th of each year if calendar year reporting is approved by the regional office. **Annual compliance certifications should be mailed to the following addresses:**

**Division for Air Quality  
London Regional Office  
85 State Police Road  
Reg. St. Office Building  
London, KY 40741-9008**

**Division for Air Quality  
Central Files  
803 Schenkel Lane  
Frankfort, KY 40601**

**U.S. EPA Region IV  
Air Enforcement Branch  
Atlanta Federal Center  
61 Forsyth St.  
Atlanta, GA 30303-8960**

8. In accordance with Regulation 401 KAR 50:035, Section 23, the permittee shall provide the division with all information necessary to determine its subject emissions within thirty (30) days of the date the KEIS emission report is mailed to the permittee.
9. Pursuant to Section VII.3 of the policy manual of the Division for Air Quality as referenced by Regulation 401 KAR 50:016, Section 1(1), results of performance test(s) required by the permit shall be submitted to the division by the source or its representative within forty-five days after the completion of the fieldwork.

**SECTION G - GENERAL CONDITIONS****(a) General Compliance Requirements**

1. The permittee shall comply with all conditions of this permit. A noncompliance shall be (a) violation(s) of state regulation 401 KAR 50:035, Permits, Section 7(3) and of Federal Statute 42 USC 7401 through 7671q (the Clean Air Act) and is grounds for enforcement action including but not limited to the termination, revocation and reissuance, or revision of this permit.
2. The filing of a request by the permittee for any permit revision, revocation, reissuance, or termination, or of a notification of a planned change or anticipated noncompliance, shall not stay any permit condition.
3. This permit may be revised, revoked, reopened and reissued, or terminated for cause. The permit will be reopened for cause and revised accordingly under the following circumstances:
  - a. If additional applicable requirements become applicable to the source and the remaining permit term is three (3) years or longer. In this case, the reopening shall be completed no later than eighteen (18) months after promulgation of the applicable requirement. A reopening shall not be required if compliance with the applicable requirement is not required until after the date on which the permit is due to expire, unless this permit or any of its terms and conditions have been extended pursuant to Regulation 401 KAR 50:035, Section 12(2)(c);
  - b. The Cabinet or the U. S. EPA determines that the permit must be revised or revoked to assure compliance with the applicable requirements;
  - c. The Cabinet or the U. S. EPA determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit;

Proceedings to reopen and reissue a permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of the permit for which cause to reopen exists. Reopenings shall be made as expeditiously as practicable. Reopenings shall not be initiated before a notice of intent to reopen is provided to the source by the division, at least thirty (30) days in advance of the date the permit is to be reopened, except that the division may provide a shorter time period in the case of an emergency.

4. The permittee shall furnish to the division, in writing, information that the division may request to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit, or to determine compliance with the permit. [401 KAR 50:035, Permits, Section 7(2)(b)3e and 401 KAR 50:035, Permits, Section 7(3)(j)]
5. The permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application, shall promptly submit such supplementary facts or corrected information to the permitting authority.

## SECTION G - GENERAL CONDITIONS (CONTINUED)

6. Any condition or portion of this permit which becomes suspended or is ruled invalid as a result of any legal or other action shall not invalidate any other portion or condition of this permit. [401 KAR 50:035, Permits, Section 7(3)(k)]
7. The permittee shall not use as a defense in an enforcement action the contention that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance. [401 KAR 50:035, Permits, Section 7(3)(e)]
8. Except as identified as state-origin requirements in this permit, all terms and conditions contained herein shall be enforceable by the United States Environmental Protection Agency and citizens of the United States.
9. This permit shall be subject to suspension if the permittee fails to pay all emissions fees within 90 days after the date of notice as specified in 401 KAR 50:038, Section 3(6). [401 KAR 50:035, Permits, Section 7(3)(h)]
10. Nothing in this permit shall alter or affect the liability of the permittee for any violation of applicable requirements prior to or at the time of permit issuance. [401 KAR 50:035, Permits, Section 8(3)(b)]
11. This permit shall not convey property rights or exclusive privileges. [401 KAR 50:035, Permits, Section 7 (3)(g)]
12. Issuance of this permit does not relieve the permittee from the responsibility of obtaining any other permits, licenses, or approvals required by the Kentucky Cabinet for Natural Resources and Environmental Protection or any other federal, state, or local agency.
13. Nothing in this permit shall alter or affect the authority of U.S. EPA to obtain information pursuant to Federal Statute 42 USC 7414, Inspections, monitoring, and entry. [401 KAR 50:035, Permits, Section 7(2)(b)5]
14. Nothing in this permit shall alter or affect the authority of U.S. EPA to impose emergency orders pursuant to Federal Statute 42 USC 7603, Emergency orders. [401 KAR 50:035, Permits, Section 8(3)(a)]
15. Permit Shield: Except as provided in State Regulation 401 KAR 50:035, Permits, compliance by the affected facilities listed herein with the conditions of this permit shall be deemed to be compliance with all applicable requirements identified in this permit as of the date of issuance of this permit.
16. All previously issued construction and operating permits are hereby null and void.

**SECTION G - GENERAL CONDITIONS (CONTINUED)****(b) Permit Expiration and Reapplication Requirements**

This permit shall remain in effect for a fixed term of five (5) years following the original date of issue. Permit expiration shall terminate the source's right to operate unless a timely and complete renewal application has been submitted to the division at least six months prior to the expiration date of the permit. Upon a timely and complete submittal, the authorization to operate within the terms and conditions of this permit, including any permit shield, shall remain in effect beyond the expiration date, until the renewal permit is issued or denied by the division. [401 KAR 50:035, Permits, Section 12]

**(c) Permit Revisions**

1. A minor permit revision procedure may be used for permit revisions involving the use of economic incentive, marketable permit, emission trading, and other similar approaches, to the extent that these minor permit revision procedures are explicitly provided for in the SIP or in applicable requirements and meet the relevant requirements of Regulation 401 KAR 50:035, Section 15.
2. This permit is not transferable by the permittee. Future owners and operators shall obtain a new permit from the Division for Air Quality. The new permit may be processed as an administrative amendment if no other change in this permit is necessary, and provided that a written agreement containing a specific date for transfer of permit responsibility coverage and liability between the current and new permittee has been submitted to the permitting authority thirty (30) days in advance of the transfer.

**(d) Construction, Start-Up, and Initial Compliance Demonstration Requirements  
Not Applicable****(e) Acid Rain Program Requirements**

1. If an applicable requirement of Federal Statute 42 USC 7401 through 7671q (the Clean Air Act) is more stringent than an applicable requirement promulgated pursuant to Federal Statute 42 USC 7651 through 7651o (Title IV of the Act), both provisions shall apply, and both shall be state and federally enforceable.

**(f) Emergency Provisions**

1. An emergency shall constitute an affirmative defense to an action brought for noncompliance with the technology-based emission limitations if the permittee demonstrates through properly signed contemporaneous operating logs or other relevant evidence that:



**SECTION G - GENERAL CONDITIONS (CONTINUED)**

- a. An emergency occurred and the permittee can identify the cause of the emergency;
    - b. The permitted facility was at the time being properly operated;
    - c. During an emergency, the permittee took all reasonable steps to minimize levels of emissions that exceeded the emissions standards or other requirements in the permit; and,
    - d. The permittee notified the division as promptly as possible and submitted written notice of the emergency to the division within two working days after the time when emission limitations were exceeded due to the emergency. The notice shall meet the requirements of 401 KAR 50:035, Permits, Section 7(1)(e)2, and include a description of the emergency, steps taken to mitigate emissions, and the corrective actions taken. This requirement does not relieve the source of any other local, state or federal notification requirements.
  2. Emergency conditions listed in General Condition (f)1 above are in addition to any emergency or upset provision(s) contained in an applicable requirement.
  3. In an enforcement proceeding, the permittee seeking to establish the occurrence of an emergency shall have the burden of proof. [401 KAR 50:035, Permits, Section 9(3)]
- (g) Risk Management Provisions
1. The permittee shall comply with all applicable requirements of 40 CFR Part 68, Risk Management Plan provisions. If required, the permittee shall:
    - a. Submit a Risk Management Plan to U.S.EPA, Region IV with a copy to this division and comply with the Risk Management Program by June 21, 1999 or a later date specified by the U.S.EPA.
    - b. Submit additional relevant information if requested by the division or the U.S. EPA.
- (h) Ozone depleting substances
1. The permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 CFR 82, Subpart F, except as provided for Motor Vehicle Air Conditioners (MVACs) in Subpart B:
    - a. Persons opening appliances for maintenance, service, repair, or disposal shall comply with the required practices contained in 40 CFR 82.156.
    - b. Equipment used during the maintenance, service, repair, or disposal of appliances shall comply with the standards for recycling and recovery equipment contained in 40 CFR 82.158.
    - c. Persons performing maintenance, service, repair, or disposal of appliances shall be certified by an approved technician certification program pursuant to 40 CFR 82.161.
    - d. Persons disposing of small appliances, MVACs, and MVAC-like appliances (as defined at 40 CFR 82.152) shall comply with the recordkeeping requirements pursuant to 40 CFR 82.166.
    - e. Persons owning commercial or industrial process refrigeration equipment shall comply with the leak repair requirements pursuant to 40 CFR 82.156.

**SECTION G - GENERAL CONDITIONS (CONTINUED)**

- f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant shall keep records of refrigerant purchased and added to such appliances pursuant to 40 CFR 82.166.
2. If the permittee performs service on motor (fleet) vehicle air conditioners containing ozone-depleting substances, the source shall comply with all applicable requirements as specified in 40 CFR 82, Subpart B, Servicing of Motor Vehicle Air Conditioners.

**SECTION H - ALTERNATE OPERATING SCENARIOS**

None

**SECTION I - COMPLIANCE SCHEDULE**

None